

200-442  
11

# REVIEW OF THE BLUE ISLAND MUNICIPAL WATER AND ELECTRIC LIGHTING PLANT

BY

ARTHUR GARFIELD DIEFENBACH

---

## THESIS

FOR THE  
DEGREE OF BACHELOR OF SCIENCE  
IN  
ELECTRICAL ENGINEERING

IN THE  
COLLEGE OF ENGINEERING

---

UNIVERSITY OF ILLINOIS

PRESENTED JUNE, 1904

UNIVERSITY OF ILLINOIS

May 27, 1904 190

THIS IS TO CERTIFY THAT THE THESIS PREPARED UNDER MY SUPERVISION BY

DIEFENBACH, ARTHUR GARFIELD

ENTITLED REVIEW OF BLUE ISLAND (ILL.) ELECTRIC POWER PLANT

IS APPROVED BY ME AS FULFILLING THIS PART OF THE REQUIREMENTS FOR THE DEGREE

OF Bachelor of Science in Electrical Engineering

Morgan Brooks

HEAD OF DEPARTMENT OF Electrical Engineering

66168

## CONTENTS

---

Part. I. Review of the Blue Island Municipal Water and Electric Lighting Plant.

Part II. Proposed location and plans for a new Municipal Water and Electric Lighting Plant.

Part III. Estimated cost of a new plant and the justification for its erection.

Part 1.

REVIEW OF THE BLUE ISLAND MUNICIPAL WATER AND ELETRIC  
LIGHTING PLANT.

The Blue Island Power plant is owned and operated by the City of Blue Island, Illinois. The purposes of the plant are to furnish water to the city, and to supply electric lights for streets, residences and business houses. The plant, as it now stands, is the result of intermittent enlargements to meet the increasing demands upon it.

The buildings are three in number, but joined together so as to almost have the appearance of one. They are constructed of common brick. The first building erected is now used by the fire department. It is two stories in height with a flat roof. The engine-dynamo room is in a two story, flat roofed building with basement. The floors in these buildings are of wood. The boiler room has a cornugated iron, gable roof. The arrangement of the buildings and their contents, together with dimensions, are given in the accompanying plans.

The boilers consist of four one hundred horse power, horizontal tubular boilers, run at a pressure of from 85 to 90 lbs. The products of combustion are carried to a six-foot steel smoke stack, 110 feet high. Two worthington feed pump with 7 $\frac{1}{2}$  " steam cylinder, 5 " water cylinder, and 6 " stroke are used to feed the boilers with river water and condensed steam from a feed water heater. This heater consists of a vertical cyclindrical shell through the centre of which passes, for two thirds the shells height, the exhaust

The dynamos consist of two 65 K.W. alternating current, 1100 volt National Electric Co's machines, run at 1500 r.p.m; also a 120 K.W., 1100 volt, Warren inductor type machine run at 800 r.p.m all single phase. These dynamos are belt connected to the above engines.

The switch board is built mostly of wood. A marble panel for the Warren machine and one for one of the National machines and a wooden panel for the other National machine are set in the wooden switch board and have mounted on them the ammeters, voltmeters, potential indicators, switches, rheostats and ground detectors of their respective machines. The switches for the distribution of current to the different circuits are mounted on the space about the panels. Fuses for the various circuits and Wurts non-arcing arresters are mounted at the top of the switch board. See switch-board wiring diagram and photographs. From this diagram of connections it will be seen that current from any one of the dynamos can be switched to any feeder circuit.

The city streets are lighted by the Electric Appliance Co's 1200 candle power 6.8 ampere, enclosed series arc lamps, and by 32 candle power series incandescent lamps. These lamps (See drawing of city circuits and location <sup>of</sup> lamps) are arranged on three circuits. The current at the plant is stepped up to two thousand volts by two J.Holt Gates & Co's and one Westinghouse 15 K.W. transformers, one transformer for each of the three circuits. The circuits are regulated by three Manhattan General Construction Co's series, alternating regulators. Two of these circuits are protected by the Garton lightning arresters and the third by the Wurts non-arcing metal arrester.



Current is distributed to the residence and business districts by four two wire circuits from the plant at a pressure of about 1100 volts. By means of transformers the service current is taken into buildings at a secondary pressure of 52 volts. There are now in use 140 transformers of from 10 to 250 lights capacity each, with an aggregate capacity of 4945 lights.

The following is a table of expenses and returns of the plant for two years:

From April 1, 1901 to April 1, 1902.

Expenses.

|                                 |       |        |          |
|---------------------------------|-------|--------|----------|
| Chief Engineer                  | ----- | \$1500 |          |
| Assist. "                       | ----- | 900    |          |
| 3 Fireman                       | ----- | 2160   |          |
| City Electrician                | ----- | 1200   | 5760     |
| 4000 tons coal                  | ----- |        | 8400     |
| Hauling coal (Extra man & team) | ----- |        | 1400     |
| 12 bbls Engine oil              | ----- | 258    |          |
| 12 " Dynamo "                   | ----- | 216    |          |
| 2 Bales Waste                   | ----- | 50     |          |
| Carbons                         | ----- | 60     |          |
| 300-32 c.p. Street lights       | ----- | 111    | 695      |
| Feed Water                      | ----- |        | 350      |
|                                 |       | Total  | \$16,605 |

Returns.

|                |       |                  |
|----------------|-------|------------------|
| Light Receipts | ----- | 7499.68          |
| Water Tax      | ----- | 6367.59          |
|                |       | <u>13867.27</u>  |
| Street Lights  | ----- | 2737.73          |
|                |       | <u>16,605.00</u> |

From April 1, 1902 to April 1, 1903.

Expenses.

|                                 |               |
|---------------------------------|---------------|
| Salaries                        | \$5760        |
| 4000 tons coal                  | 8600          |
| Hauling coal (Extra man & team) | 1400          |
| Supplies                        | 695           |
| Feed Water                      | 350           |
|                                 | <u>16,805</u> |

Returns.

|                              |                 |
|------------------------------|-----------------|
| Light Receipts. (Commercial) | \$6448.81       |
| Water Tax                    | 5942.85         |
|                              | <u>12391.66</u> |
| Street Lights.               | 4413.34         |
|                              | <u>16805.00</u> |

A valuation of \$135,500 has been made on the real estate, buildings, installed machinery and connections and outside distributing system of the plant. As this valuation of the plant seems excessive for one of its size, and the plant could to-day be replaced for much less money by a plant located near a railroad, so as to bring about a saving of about twenty five cents drayage per ton of coal burned and a saving of about \$350 a year for river water now purchased from the Rock Island Ry, it is advisable to build an up-to-date plant near the creek and railroad. The following is a design of a water and electric light plant suitable for the present and possible future needs of the city.



Views of the Blue Island Water and Electric Lighting  
Plant.








Blue Island Plant from the West.



Blue Island Plant from the East.




Large Air Lift.



Pumps and Small Air Lifts.




Armstrong and small "Ideal" Engines.



Large "Ideal" Engine.





PLAN  
OF THE  
BLUE ISLAND  
MUNICIPAL PLANT

1903

A. G. Diefenbach '04.

SCALE  $\frac{1}{16}'' = 10'$


steam pipe. The steam shoots against an arched baffle plate on which plays a fine spray of river water coming out of a perforated pipe above the plate. The cold river water is stored above the heater in a boiler-plate tank, and surplus water from the heater is run into a tank similar to the first mentioned, from which it is pumped to the boilers.

The City's water supply is obtained from two artesian wells, one 1327 and the other 1409 feet deep with the water 150 feet from the surface. The water is raised from these wells by compressed air, and run into two cisterns, connected together at the bottom, and of about 51,500 gallons total capacity. The water is pumped from these cisterns directly into the water mains, and allowed to back up into a 22000 gallon wooden tank, the bottom of which is 50 feet above ground. The tank rests on a circular stone foundation three and a half foot thick. On the hill where the plant is situated the pressure is only 21 lbs per sq. in. and below it is about 41 lbs.

The three air lift pumps are of the Rand Drill Co's make. The two old ones are each 80 HP with a capacity of 150 gallons per minute. The new one is 180 HP and can lift about 1000 gallons per minute. The pressure of the air at starting is 100 lbs per sq. in. but only 85 lbs when the water is flowing. The two pumps for pumping the water into the mains are of the Volker & Felthousen M'fg Co's and the Wheeler & Tappan's make the former with a capacity of 700 gallons per minute, and the latter with 640.

Three engines are used to run the dynamos. One is an Armstrong & Son's 100 H.P., and the other two are A.L. Ide & Son's "Ideal" 100 and 180 H.P.










The two National Generators.



The Warren Generator.





Main Switch board.



Arc Light Transformers,  
Manhattan Regulators, Ammeters and Lightning Arresters.

Part II.

PROPOSED LOCATION AND PLANS FOR A NEW BLUE ISLAND MUNICIPAL  
WATER AND ELECTRIC LIGHTING PLANT.

Location.

A good location for a new water and electric lighting plant for the City of Blue Island would be west of the Chicago & Grand Trunk R.R. and north of Vermont Street. Here coal could be taken directly from the cars to the boiler house bin, and soft water for the boilers could be pumped from the near-by creek. See tracing of the lighting circuits of the city and note red cross for the above location.

Plans.

The accompanying drawing shows the size of the proposed building, its contents and their arrangement, the city water reservoir and the coal storage bin. New apparatus is to be installed, excepting, perhaps, the new air lift now in use.

The contents of the new building is to be as follows:-

3-200 H.P. Water tube boilers with superheater) steam pressure  
200 lbs)

2- Feed water pumps.

1 Vacuum pump.

1 motor driven centrifugal pump.

1 Surface condenser.

1 Air Lift.

2 City supply water pumps.

2-300 H.P., 200 A.W., 2 Phase De Laval steam turbine alternators.



Outside the building will be a hot well, a steel smoke stack 6 feet in diameter and 120 feet high, a 112,000 gal. city water supply concrete reservoir and a coal storage bin. Coal shoveled from the cars into this bin rolls down in front of the boilers.

It is proposed to continue using the old artesian wells. Compressed air piped to the wells will raise the water and deliver it to the new reservoir forty feet below the tops of the artesian wells. Thus it will be possible to do away with any attendant at the old plant.

The distribution system for lighting is to be three wire, two phase without transformers for 220-volt lamps.




Fig. 25.—De Laval Steam Turbine Alternator, 300 H. P., 200 K. W., Two Phase.

112000 GAL CITY  
WATER RESERVOIR  
DEPTH 10' SCALE  $\frac{1}{2}''=1'$

62'-0"

27'-0"

90'-0"

56'-0"

34'-0"

AIR  
LIFT

2

WATER  
PUMP

3

4

5

WATER  
PUMP

1

FUTURE  
UNIT

2

1

(1&2) DELAVAL STEAM  
TURBINE ALTERNATOR, 300  
HP, 200K W, 2 PHASE  
(3) CONDENSER  
(4) CENTRIFUGAL  
PUMP  
(5) VACUUM PUMP

SWITCH BOARD

OFFICE

200 H.P. WATER TUBE BOILERS

1&amp;2 FEED WATER PUMPS

COAL

COAL STORAGE

HOT  
WELL

TOP

STEEL SMOKE  
STACK 120' HIGH,  
6 IN DIAMETER

BASE

SECTION  
THROUGH AB

45'-0"

14'-0"

SIDE TRACK OF  
CHICAGO & GRAND TRUNK R. R.

SCALE  $\frac{1}{8}''=1'$ 

PROPOSED PLAN  
OF NEW  
BLUE ISLAND  
MUNICIPAL PLANT

R. B. Rosenthal '14

Part III.

ESTIMATED COST OF A NEW PLANT AND THE JUSTIFICATION FOR ITS  
ERECTION.

A new plant for the city is needed. The old plant has been in use for some time, and its equipment is not in good condition to give either first class or economical service. A new plant would effect a saving in several directions. The expense of hauling coal from the railroad to the old plant, a distance of three blocks, would be saved. As this expense now amounts to thirty-five cents per ton, allowing ten cents per ton for unloading the coal, a saving of at least twenty-five cents per ton would be made. Figuring on the amount of coal now burned, about \$1000 would be saved on the item of hauling. The city now pays about \$350 per year for river water purchased from the railroad. A plant located near the creek could pump its own water for the boilers and so save the amount paid to the railroad. At least \$2000 will be saved on the coal bill on account of better efficiency of the new equipment. The sum saved by the new plant will then be in the neighborhood of \$4350. By doing away with the transformer a sum of \$1000 will be saved in transform losses in figuring the plant operated twelve hours a day. If the plant was operated all day, twice the amount would be saved. Figuring at the rate of ten per cent for depreciation and interest, the \$4350 saved would make it advisable to construct a better plant to an increased amount not exceeding \$43500.

The following is an estimate of the cost of a new plant:-



|  |         |
|--|---------|
| Land   | \$2000  |
| Building                                       | 15000   |
| 3-200 H.P. Water Tube Boilers with superheater | 12000   |
| 2 Feed Pumps.                                  | 200     |
| 1 Vacuum Pump                                  | 125     |
| 1 Surface Condenser                            | 600     |
| 1 Centrifugal Pump and Motor.                  | 200     |
| 2-200 K.W. De Leval Steam Turbine Alternators. | 18000   |
| Switchboard                                    | 500     |
| 2 City Water Supply Pumps.                     | 2500    |
| Piping   | 600     |
| Reservoir.                                     | 600     |
| Steel Smoke Stack.                             | 1200    |
| Hot Well.                                      | 75      |
| Coal Storage Bin.                              | 300     |
|  | <hr/>   |
|  | \$53900 |

By subtracting \$43500, the amount on which the saving of the new plant will pay depreciation and interest charges, from \$53900, the estimated cost of the new plant, a sum of \$10,400 is left as the unproductive cost of the new plant. The sale of most the equipment of the old plant would reduce this cost still further.

Such new water and electric lighting plant as described in Part II is very much needed to ensure reliability of service, and since a considerable saving in operating expenses would be effected, a reduction in charges would stimulate rapid growth.